



**Montana Environmental Laboratory LLC**  
1170 N. Meridian Rd. P.O. Box 8900 Kalispell, MT 59904  
Ph: 406-755-2131 Fax: 406-257-5359 [www.melab.us](http://www.melab.us)

# Sulfates and Hydrogen Sulfide

## Rotten Egg / Sulfur Smell

## Sulfate Reducing Bacteria

Two forms of sulfur are commonly found in drinking water supplies: sulfate and hydrogen sulfide. Both forms are nuisances that usually do not pose a health risk at the concentrations found in domestic water supplies.

### **Sources of sulfate and hydrogen sulfide in drinking water**

#### **Sulfates**

Sulfates are a combination of sulfur and oxygen and are a part of naturally occurring minerals in some soil and rock formations that contain groundwater. The mineral dissolves over time and is released into groundwater.

#### **Hydrogen sulfide**

Sulfur-reducing bacteria, which use sulfur as an energy source, are the primary producers of large quantities of hydrogen sulfide. These bacteria chemically change natural sulfates in water to hydrogen sulfide. Sulfur-reducing bacteria live in oxygen-deficient environments such as deep wells, plumbing systems, water softeners and water heaters. These bacteria usually flourish on the hot water side of a water distribution system.

Hydrogen sulfide gas also occurs naturally in some groundwater. It is formed from decomposing underground deposits of organic matter such as decaying plant material. It is found in deep or shallow wells and also can enter surface water through springs, although it quickly escapes to the atmosphere. Hydrogen sulfide often is present in wells drilled in shale or sandstone, or near coal or peat deposits or oil fields. Occasionally, a hot water heater is a source of hydrogen sulfide odor. The magnesium corrosion control rod present in many hot water heaters can chemically reduce naturally occurring sulfates to hydrogen sulfide.

### **Indications of Sulfate and Hydrogen Sulfide**

#### **Sulfate**

Sulfate minerals can cause scale buildup in water pipes similar to other minerals and may be associated with a bitter taste in water that can have a laxative effect on humans and young livestock. Elevated sulfate levels in combination with chlorine bleach can make cleaning clothes difficult.

Sulfur-oxidizing bacteria produce effects similar to those of iron bacteria. They convert sulfide into sulfate, producing a dark slime that can clog plumbing and/or stain clothing. Blackening of water or dark slime coating the inside of toilet tanks may indicate a sulfur-oxidizing bacteria problem. Sulfur-oxidizing bacteria are less common than sulfur-reducing bacteria.

#### **Hydrogen Sulfide**

Hydrogen sulfide gas produces an offensive "rotten egg" or "sulfur water" odor and taste in the water. In some cases, the odor may be noticeable only when the water is initially turned on or when hot water is run. Heat forces the gas into the air which may cause the odor to be especially offensive in a shower. Occasionally, a hot water heater is a source of hydrogen sulfide odor. The magnesium corrosion control rod present in many hot water heaters can chemically reduce naturally occurring sulfates to hydrogen sulfide.

A nuisance associated with hydrogen sulfide includes its corrosiveness to metals such as iron, steel, copper and brass. It can tarnish silverware and discolor copper and brass utensils. Hydrogen sulfide also can cause yellow or black stains on kitchen and bathroom fixtures. Coffee, tea and other beverages made with water containing hydrogen sulfide may be discolored and the appearance and taste of cooked foods can be affected.

High concentrations of dissolved hydrogen sulfide also can foul the resin bed of an ion exchange water softener. When a hydrogen sulfide odor occurs in treated water (softened or filtered) and no hydrogen sulfide is detected in the non-treated water, it usually indicates the presence of some form of sulfate-reducing bacteria in the system. Water softeners provide a convenient environment for these bacteria to grow. A "salt-loving" bacteria, that uses sulfates as an energy source, may produce a black slime inside water softeners.

## **Potential Health Effects**

### **Sulfate**

Sulfate may have a laxative effect that can lead to dehydration and is of special concern for infants. With time, people and livestock will become acclimated to the sulfate and the symptoms disappear. Sulfur-oxidizing bacteria pose no known human health risk. The Maximum contaminant level for sulfate is 250 mg/L.

### **Hydrogen Sulfide**

Hydrogen sulfide is flammable and poisonous. Usually it is not a health risk at concentrations present in household water, except in very high concentrations. While such concentrations are rare, hydrogen sulfide's presence in drinking water when released in confined areas has been known to cause nausea, illness and, in extreme cases, death. Water with hydrogen sulfide alone does not cause disease. In rare cases, however, hydrogen sulfide odor may be from sewage pollution which can contain disease-producing contaminants. **Therefore, testing for coliform bacterial contamination and sulfate reducing bacteria is highly recommended.**

## **Water testing**

### **Sulfate**

Montana Environmental Lab can provide you with an appropriate bottle, and a sulfate test is \$15. Testing for iron or sulfate bacteria costs \$45 per sample.

## **Interpreting sulfate and hydrogen sulfide test results**

### **Sulfate**

The Environmental Protection Agency (EPA) standards for drinking water fall into two categories; Primary Standards and Secondary Standards. Primary Standards are based on health considerations and are designed to protect people from three classes of toxic pollutants; pathogens, radioactive elements and toxic chemicals. Secondary Standards are based on taste, odor, color, corrosivity, foaming and staining properties of water. Sulfate is classified under the secondary maximum contaminant level (SMCL) standards. The SMCL for sulfate in drinking water is 250 milligrams per liter (mg/l), sometimes expressed as 250 parts per million (ppm).

### **Hydrogen sulfide**

Although many impurities are regulated by Primary or Secondary Drinking Water Standards set by the EPA, hydrogen sulfide is not regulated because a concentration high enough to be a drinking water health hazard also makes the water unpalatable.

The odor of water with as little as 0.5 ppm of hydrogen sulfide concentration is detectable by most people. Concentrations less than 1 ppm give the water a "musty" or "swampy" odor. A 1-2 ppm hydrogen sulfide

concentration gives water a "rotten egg" odor and makes the water very corrosive to plumbing. Generally, hydrogen sulfide levels are less than 10 ppm, but have been reported as high as 50 to 75 ppm.

## Options

If excessive sulfate or hydrogen sulfide is present in your water supply, you have three basic options -- obtain an alternate water supply, bottled water, or use some type of treatment to remove the impurity. The need for an alternate water supply or impurity removal should be established before making an investment in treatment equipment or an alternate supply. Base the decision on a water analysis by a reputable laboratory and after consulting with your physician to help you evaluate the level of risk. It may be possible to obtain a satisfactory alternate water supply by drilling a new well in a different location or a shallower or deeper well in a different aquifer. Another alternate source of water is bottled water that can be purchased in stores or direct from bottling companies. This alternative might be considered especially when the primary concern is water for food preparation and drinking. The typical recommendation is the installation of a whole house treatment system. The selection of the most cost effective system is a function of the overall water quality, cause of the sulfur odor, and other water treatment issues.

## Sulfate treatment

Several methods of removing sulfate from water are available. The treatment method selected depends on many factors including the level of sulfate in the water, the amount of iron and manganese in the water, and if bacterial contamination also must be treated. The option you choose also depends on how much water you need to treat. For treating small quantities of water (drinking and cooking only) the typical methods may be distillation or reverse osmosis. The most common method of treating large quantities of water is *ion exchange*. This process works similar to a water softener. Ion-exchange resin, contained inside the unit, adsorbs sulfate. When the resin is loaded to full capacity with sulfate, treatment ceases. The resin then must be "regenerated" with a salt (sodium chloride) brine solution before further treatment can occur. *Distillation* boils water to form steam that is then cooled and then recondensed. Minerals, such as sulfate, do not vaporize with the steam and are left behind in the boiling chamber. *Reverse osmosis* membranes have a porosity that permits water molecules to pass through but leaves the large ions in solution.

## Hydrogen sulfide

Hydrogen sulfide may be temporarily controlled by conducting a shock chlorination / disinfection of the well or water source. Please look at our Shock Chlorination report to get more information on this protocol. If the problem with the well is because of Sulfate Reducing Bacteria, a high level of chlorination, mixing, and turbulence may be needed. There are companies who specialize in this kind of well rehabilitation.

If hydrogen sulfide odor is associated primarily with the hot water system, a hot water heater modification may reduce the odor. Replacing the water heater's magnesium corrosion control rod with one made of aluminum or another metal may improve the situation.

To remove low levels of hydrogen sulfide, install an activated carbon filter. The filter must be replaced periodically to maintain performance. Frequency of replacement will depend on daily water use and concentration of hydrogen sulfide in the water.

Hydrogen sulfide concentrations up to about 6 ppm can be removed using an oxidizing filter (same as an iron filter). This filter contains sand with a manganese dioxide coating that changes hydrogen sulfide gas to tiny particles of sulfur that are trapped inside the filter. The sand filter must be backflushed regularly and treated with potassium permanganate to maintain the coating.

Hydrogen sulfide concentrations exceeding 6 ppm can be removed by injecting an oxidizing chemical such as household bleach or potassium permanganate and using a filter. The oxidizing chemical should enter the water upstream from the storage or mixing tank to provide at least 20 minutes of contact time between the chemical and water. Sulfur particles can then be removed using a sediment filter. Excess chlorine can be removed by activated carbon filtration. When potassium permanganate is used a manganese greensand filter

is recommended. Often the treatment for hydrogen sulfide is the same as for iron and manganese.

In closing, sulfates and hydrogen sulfide are both common nuisance contaminants. Although neither is usually a significant health hazard, sulfates can have a temporary laxative effect on humans and young livestock. Sulfates also may clog plumbing and stain clothing. Hydrogen sulfide produces an offensive "rotten egg" odor and taste in the water, especially when the water is heated. Treatment options depend on the form and quantities in which sulfates and/or hydrogen sulfide occur in untreated water. Therefore, it is critical that a comprehensive water analysis be conducted. Small quantities of sulfate may be removed from water using distillation or reverse osmosis, while large quantities may be removed using ion exchange treatment. Hydrogen sulfide gas may be associated with the presence of Sulfate Reducing Bacteria. Hydrogen sulfide may be reduced or removed by shock chlorination, water heater modification, activated carbon filtration, oxidizing filtration or oxidizing chemical injection. Often treatment for hydrogen sulfide is the same as for iron and manganese, allowing the removal of all three contaminants in one process.

**Note: It is critical that the water be tested prior to selecting a treatment system. A rotten egg smell could be several things, including sulfate reducing bacteria, and or elevated levels of hydrogen sulfide, iron, manganese.**